Non Domestic Gas Safety Record

Cert. No. 161

Clima Heating Services Ltd

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure No detailed internal inspection of flues (integrity, construction and lining) has been carried out.

Company / Installer

Engineer	[redacted]
Company	Clima Heating Services Ltd
Address	14
	Flockton Crescent
	Sheffield
	South Yorkshire
Post Code	S13 9QR
Tel No.	[redacted]
Gas Safe Reg	[redacted]
ID Card No.	[redacted]

Job Address

Name	University Of Sheffield Accommodation Village
Address	Crewe Hall Bishops House Flat 5
	Crewe Hall
	Sheffield
	South Yorkshire
Post Code	S10 3EA
Tel. No	01142 224948

Customer / LandLord

Name	[redacted]
Company	Engie
Address	14
	Endcliffe Avenue
	Sheffield
	South Yorkshire
Post Code	S10 3EA
Tel. No	01142 224948

Appliance Details / Inspection Details

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Boiler	Viessmann	VITODENS 200	RS	Yes	Yes	20.6	NA	0.0006	57	9.3	0.0002	16	9.6	Yes	Yes	Yes	Pass	Yes	Yes
2																					
3																					
4																					
5																					
6																					

Defects / Identified

		Labels and Warning Notice Issued
1	Appliance in poor condition, recommend look at replacing	No
2		
3		
4		
5		
6		

Emergency Control Accessible No

Gas Tightness Satisfactory NA

Gas Installation Pipework Visual Inspection Satisfactory No

Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE 28-May-2022

Comments

No AECV installed inside/locally to the property

Signatures

Issued by: Signed [redacted]

Print Name [redacted]

Received by: Signed

Print Name [redacted]

Date 28-May-2021